

POLE MIDSPAN MEASUREMENT WORKSHEET / WIND LOAD

F001-22-0006M

Pole # 1

CATV / TEL MAKE-READY REQUIRED				UTILITY MAKE-READY REQUIRED				Y
NUMBER OF LANES	4	R/W ACCESSIBLE		Y	NEXT SPAN DIR	N	MS X-ING	RWA
POLE SPAN LENGTH					PRIMARY FRAMING		SET DEPTH	6
PREVIOUS		NEXT	93		# OF PHASES		EWL	

ATTACH	LIC	QTY	P-SIZE	N-SIZE	JUNCT	HEIGHT	HEIGHT ADJ	MS HEIGHT	MS ADJ	MOMENT
TPX			1/0T			26.33		18.67		393.89
SDL						24.67				
SR	UGD		2"			24.67				707.29

PROPOSED WIRELINE ATTACHMENTS

PROPOSED WIRELESS ANTENNA ATTACHMENTS

TYPE	LIC	N/E	LENGTH	AREA	BOTTOM	HEIGHT ADJ	TOP	MOMENT
POLE TOP	01	N	4	3.86	33.5		37.5	102.77

OWNER	FPL	MATERIAL	W	HEIGHT / CLASS	35	/	4	CALC	1203.95
UTILITY MAP	EB-0958	BRAND YEAR	2014	JUNCT,S-GUY or SPLINT				ALLOW	14835.00
ADDRESS	201 GRANADA BLVD							WIND LOAD	PASS
TLN				ADJUSTED ALLOWABLE					
INSP BY	JIM SMITH	DATE	3/15/2022	GPS COORDINATES				29.426828,-81.189719	
COMMENTS	FPL TO SET A 40/2 POLE								